



## **ADDENDUM NO.1**

**FOR**

**SUPPLY OF MATERIALS FOR RE-CONDUCTORING RUGONJO-  
NKENDA 132KV TRANSMISSION LINE**

**REFERENCE NO: UETCL/SUPLS/2025-2026/00028**

This is to issue Addendum No. 1 to the Bidding Document.



This addendum amends the list of supplies and related services and the specifications and closing date to bidders and the Bid Data Sheet of the Bidding Document.

As Bidding Document				Amendment to read as															
Page 64 List of supplies and related services	See the attached previous list of supplies on the quantities for items no. 1, 16 and 20 versus the quantities in the specifications				<div>The bidders should consider the following amended quantities.</div> <table><tr><td>No</td><td>Description</td><td>Quantity</td></tr><tr><td>1</td><td>200sqmm AAAC conductor</td><td>135</td></tr><tr><td>16</td><td>¾*14 eye bolts &amp; nuts</td><td>1635</td></tr><tr><td>20</td><td>Safety belts</td><td>9</td></tr></table>			No	Description	Quantity	1	200sqmm AAAC conductor	135	16	¾*14 eye bolts & nuts	1635	20	Safety belts	9
	No	Description	Quantity																
	1	200sqmm AAAC conductor	135																
	16	¾*14 eye bolts & nuts	1635																
	20	Safety belts	9																
		List of supplies in the bid document		Quantities for the specifications															
No	Description	Quantity	Qty																
1	200sqmm AAAC conductor	135	123																
16	¾*14 eye bolts & nuts	1835	1635																
20	Safety belts	9	8																
ITB. 24.1, 27.1, Abridged bid notice item no. 1, invitation to bidders item no. 6 , 8 and 12 (c)	The deadline for submission shall be at 11:00am on 1 <sup>st</sup> October, 2025, to the address below;  Uganda Electricity Transmission Company Limited Plot 12 Hannington Road, Procurement Office – 2nd Floor Annex				The deadline for submission shall be at 11:00am on 22 <sup>nd</sup> October, 2025 to the address below;  Uganda Electricity Transmission Company Limited Plot 12 Hannington Road, Procurement Office – 2nd Floor Annex														
Page 8 of the conductors specifications	The number of strands for the conductor is 17.  Rated strength for the conductor is 59.10kN				The number of strands for the conductor is 19.  Minimum rated strength to be 59.10kN as per BS 3242. Higher rated strength is acceptable														
Specifications: strain clamps of the specifications	mechanical failing load (MFL) of the tension/strain clamps is 20000LBS				The strain clamps should be 25000LBS														



Adjusted Procurement Schedule (subject to changes) is as follows:

Bid Closing Date	22 <sup>nd</sup> October, 2025
Opening date	22 <sup>nd</sup> October, 2025
Evaluation	28 <sup>th</sup> October -10 <sup>th</sup> November, 2025
Display & Communication of best evaluated bidder notice	17 <sup>th</sup> – 28 <sup>th</sup> November, 2025
Contract Award & Signature	After Expiry of BEB and obtaining all the necessary approvals

Note: All other content in the Bidding Document not amended by this addendum No.1 remain the same.

### MANAGEMENT

